



# Certificate of Compliance

Certificate:

80011314

Master Contract: 600507

Project:

80011314

Date Issued:

2019-08-01

Issued to:

Jonsol GmbH Bergweg 82

Aidlingen, Baden-Württemberg 71134

**GERMANY** 

Attention: Carsten Halle

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Chris Wang Chris Wang

#### **PRODUCTS**

CLASS 5311 10 - POWER SUPPLIES - Photovoltaic Modules and Panels CLASS 5311 90 - POWER SUPPLIES - Photovoltaic Modules and Panels - Certified to U.S. Standards

Photovoltaic Modules with Maximum System Voltage of 1000 V dc or 1500 V dc, Module Fire Performance Type 1 (for US) / Fire Resistance Rating Class C (for Canada). Model Series JSP72-xxx (xxx=295-375), JSP60-xxx (xxx=250-310), JSPB72-xxx (xxx=295-370), JSPB60-xxx (xxx=250-305), JSM72-xxx (xxx=340-400), JSM60-xxx (xxx=280-330), JSMB72-xxx (xxx=340-400), JSMB60-xxx (xxx=280-330), with the electrical ratings at Standard Test Conditions.

## Notes:

1. Rated electrical characteristics are within +/- 10% of measured values at Standard Test Conditions of 100 mW/cm2 irradiance, AM 1.5 spectrums, and 25°C.

### APPLICABLE REQUIREMENTS

ULC/ORD-C1703-01 -

Flat-Plate Photovoltaic Modules and Panels

UL 1703 3<sup>rd</sup> Edition

Flat-Plate Photovoltaic Modules and Panels

#### MARKINGS

Each unit shall bear all the required markings identified in the applicable certification report(s).